


## LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi 260 \times H150MM$	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi 0.26$	PROTECTION ANGLE:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 210.51 lm/W			
MODEL	UFO100W-120D	Imax(cd)	7109	S/MH(C0/180)	1.31
NOMINAL POWER(W)	101.2	LOR(%)	100.0	S/MH(C90/270)	1.31
RATED VOLTAGE(V)	230	TOTAL FLUX(lm)	21303	$\eta$ UP,DN(C0-180)	0.0,51.3
NOMINAL FLUX(lm)	21303.3	CIE CLASS	DIRECT	$\eta$ UP,DN(C180-360)	0.0,48.7
LAMPS INSIDE	1	$\eta$ up(%)	0.0	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	230.1	$\eta$ down(%)	100.0	CIBSE SHR MAX	1.50

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG  
C Interval: 90.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: chen xue chang  
Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
Humidity: 65.0%  
Test Distance: 7.300m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

## ZONAL FLUX DIAGRAM:

$\gamma$	C0	C90	C180	C270					$\gamma$	$\Phi$ zone	$\Phi$ total	%lum, lamp
10	7027	7024	6984	6983					0- 10	673.4	673.4	3.16, 3.16
20	6752	6743	6664	6671					10- 20	1944	2617	12.3, 12.3
30	6282	6266	6149	6162					20- 30	2991	5608	26.3, 26.3
40	5607	5590	5434	5444					30- 40	3687	9296	43.6, 43.6
50	4727	4704	4512	4532					40- 50	3928	13224	62.1, 62.1
60	3643	3614	3396	3419					50- 60	3654	16877	79.2, 79.2
70	2372	2351	2013	2049					60- 70	2859	19736	92.6, 92.6
80	638.5	594.2	366.2	407.4					70- 80	1394	21130	99.2, 99.2
90	90.85	90.63	66.32	66.14					80- 90	173.2	21303	100, 100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG  
 C Interval: 90.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: chen xue chang  
 Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
 Humidity: 65.0%  
 Test Distance: 7.300m [K=1.0000]  
 Remarks:

## CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi 260 \times H150MM$	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi 0.26$	PROTECTION ANGLE:

$\rho_{cc}$	80%			70%			50%			30%			10%			0
$\rho_w$	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
$\rho_{fc}$	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.04	1.00	.96	1.02	.98	.95	.98	.95	.92	.94	.91	.89	.90	.88	.86	.84
2.0	.91	.84	.78	.89	.83	.77	.85	.80	.76	.82	.78	.74	.79	.75	.72	.70
3.0	.79	.71	.65	.78	.70	.64	.75	.68	.63	.72	.67	.62	.70	.65	.61	.59
4.0	.70	.61	.55	.69	.61	.54	.66	.59	.53	.64	.58	.53	.62	.56	.52	.50
5.0	.63	.53	.47	.61	.53	.46	.59	.52	.46	.57	.51	.45	.55	.50	.45	.43
6.0	.56	.47	.41	.55	.47	.40	.53	.46	.40	.52	.45	.40	.50	.44	.39	.37
7.0	.51	.42	.36	.50	.42	.36	.48	.41	.35	.47	.40	.35	.46	.39	.35	.33
8.0	.46	.38	.32	.46	.37	.32	.44	.37	.31	.43	.36	.31	.42	.36	.31	.29
9.0	.42	.34	.29	.42	.34	.28	.41	.33	.28	.40	.33	.28	.39	.32	.28	.26
10.0	.39	.31	.26	.39	.31	.26	.38	.30	.26	.37	.30	.25	.36	.30	.25	.24



C Range: 0 - 360DEG  
 C Interval: 90.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: chen xue chang  
 Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
 Humidity: 65.0%  
 Test Distance: 7.300m [K=1.0000]  
 Remarks:

## WEC AND CCEC

NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi 260 \times H150MM$	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi 0.26$	PROTECTION ANGLE:

pcc	80%	70%	50%	30%	10%	0
pw	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
pfc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)					
0.0						
1.0	.301 .171 .054	.294 .167 .053	.280 .161 .051	.268 .155 .050	.257 .149 .048	
2.0	.289 .158 .049	.282 .156 .048	.271 .151 .047	.260 .146 .046	.250 .141 .045	
3.0	.269 .143 .043	.264 .141 .043	.253 .137 .042	.244 .134 .041	.235 .130 .040	
4.0	.249 .130 .038	.245 .128 .038	.235 .125 .037	.227 .122 .037	.219 .119 .036	
5.0	.231 .118 .034	.227 .116 .034	.219 .114 .034	.211 .111 .033	.204 .109 .033	
6.0	.215 .108 .031	.211 .106 .031	.203 .104 .030	.197 .102 .030	.190 .100 .030	
7.0	.200 .099 .028	.196 .098 .028	.190 .096 .028	.184 .094 .027	.178 .093 .027	
8.0	.187 .091 .026	.184 .090 .026	.178 .089 .025	.172 .087 .025	.167 .086 .025	
9.0	.175 .085 .024	.172 .084 .024	.167 .083 .023	.162 .081 .023	.157 .080 .023	
10.0	.164 .079 .022	.162 .078 .022	.157 .077 .022	.153 .076 .022	.149 .075 .021	

pcc	80%	70%	50%	30%	10%	0
pw	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
pfc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)					
0.0	.190 .190 .190	.163 .163 .163	.111 .111 .111	.064 .064 .064	.020 .020 .020	
1.0	.180 .156 .135	.154 .134 .116	.105 .092 .080	.061 .053 .047	.019 .017 .015	
2.0	.172 .132 .098	.147 .114 .085	.101 .079 .059	.058 .046 .035	.019 .015 .011	
3.0	.164 .114 .074	.141 .099 .065	.097 .068 .045	.056 .040 .027	.018 .013 .009	
4.0	.157 .101 .058	.135 .087 .051	.093 .061 .036	.054 .036 .021	.017 .012 .007	
5.0	.150 .091 .047	.129 .078 .041	.089 .055 .029	.051 .032 .017	.017 .010 .006	
6.0	.143 .082 .039	.123 .071 .034	.085 .050 .024	.049 .029 .014	.016 .010 .005	
7.0	.136 .075 .033	.117 .065 .029	.081 .046 .020	.047 .027 .012	.015 .009 .004	
8.0	.129 .070 .029	.111 .060 .025	.077 .042 .018	.045 .025 .011	.015 .008 .003	
9.0	.123 .065 .025	.106 .056 .022	.074 .039 .016	.043 .023 .009	.014 .008 .003	
10.0	.118 .060 .022	.101 .052 .019	.070 .037 .014	.041 .022 .008	.013 .007 .003	

C Range: 0 - 360DEG  
 C Interval: 90.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:chen xue chang  
 Test Date:2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
 Humidity:65.0%  
 Test Distance:7.300m [K=1.0000]  
 Remarks:

## Uncorrected UGR Table

NAME: LED High Bay					TYPE:					WEIGHT:				
DIM.: $\Phi 260 \times H150MM$					SPEC.:					SERIAL No.:				
MFR.:					SUR.: $\Phi 0.26$					PROTECTION ANGLE:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3				
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3				
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				
Room dimensions					Viewed crosswise					Viewed endwise				
x = 2H y = 2H					30.3	31.8	30.6	32.0	32.2	30.3	31.8	30.5	32.0	32.2
3H					32.0	33.4	32.3	33.6	33.9	31.9	33.3	32.2	33.6	33.8
4H					32.5	33.9	32.8	34.1	34.4	32.5	33.8	32.8	34.1	34.3
6H					32.8	34.0	33.1	34.3	34.6	32.7	33.9	33.0	34.2	34.5
8H					32.8	34.0	33.1	34.3	34.6	32.7	33.9	33.0	34.2	34.5
12H					32.7	33.9	33.1	34.2	34.5	32.6	33.8	33.0	34.1	34.4
4H 2H					31.0	32.3	31.3	32.6	32.8	30.9	32.3	31.3	32.5	32.8
3H					32.8	34.0	33.1	34.3	34.6	32.8	33.9	33.1	34.2	34.5
4H					33.4	34.5	33.8	34.8	35.2	33.4	34.5	33.8	34.8	35.1
6H					33.7	34.7	34.1	35.0	35.4	33.7	34.6	34.1	35.0	35.3
8H					33.8	34.7	34.2	35.0	35.4	33.7	34.6	34.1	34.9	35.3
12H					33.7	34.6	34.2	34.9	35.3	33.7	34.5	34.1	34.9	35.3
8H 4H					33.6	34.5	34.1	34.9	35.3	33.6	34.5	34.0	34.9	35.2
6H					34.0	34.7	34.5	35.2	35.6	34.0	34.7	34.4	35.1	35.5
8H					34.1	34.7	34.5	35.1	35.6	34.0	34.6	34.5	35.1	35.5
12H					34.1	34.6	34.5	35.1	35.5	34.0	34.5	34.5	35.0	35.5
12H 4H					33.6	34.4	34.1	34.8	35.2	33.6	34.4	34.0	34.8	35.2
6H					34.0	34.7	34.5	35.1	35.5	34.0	34.6	34.4	35.0	35.5
8H					34.1	34.6	34.6	35.1	35.6	34.0	34.6	34.5	35.0	35.5
Variations with the observer position at spacings:														
S = 1.0H					+ 0.1 / - 0.2					+ 0.1 / - 0.2				
1.5H					+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H					+ 0.2 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117 Corrected 21303 lm Total Lamp Luminous Flux. (8log(F/F0) = 10.6)

C Range: 0 - 360DEG  
 C Interval: 90.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: chen xue chang  
 Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
 Humidity: 65.0%  
 Test Distance: 7.300m [K=1.0000]  
 Remarks:


```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.269
Humidity:65.0%
Test Distance:7.300m [K=1.0000]
Remarks:

```

## ISOCANDELA DIAGRAM

NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi 260 \times H150MM$	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi 0.26$	PROTECTION ANGLE:




C Range: 0 - 360DEG  
C Interval: 90.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: chen xue chang  
Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
Humidity: 65.0%  
Test Distance: 7.300m [K=1.0000]  
Remarks:

### AAI Figure

NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi$ 260*H150MM	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi$ 0.26	PROTECTION ANGLE:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.


C Range: 0 - 360DEG  
C Interval: 90.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: chen xue chang  
Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
Humidity: 65.0%  
Test Distance: 7.300m [K=1.0000]  
Remarks:



### ISOLUX DIAGRAM


NAME: LED High Bay	TYPE:	WEIGHT:
DIM.: $\Phi 260 \times H150MM$	SPEC.:	SERIAL No.:
MFR.:	SUR.: $\Phi 0.26$	PROTECTION ANGLE:



C Range: 0 - 360DEG  
C Interval: 90.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: chen xue chang  
Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
Humidity: 65.0%  
Test Distance: 7.300m [K=1.0000]  
Remarks:

## Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 90.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: chen xue chang  
Test Date: 2022-05-13

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.0.269  
Humidity: 65.0%  
Test Distance: 7.300m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.269
Humidity:65.0%
Test Distance:7.300m [K=1.0000]
Remarks:

```